

PV (Solar) Site Information



Legend	
Disconnection point	
4mm DC cable	
16mm AC cable	
DC Optimiser	

- Notes:**
1. The installation shall be completed by a licensed electrical contractor as per relevant Australian Standards
 2. The cables/switches shall be designed and installed as per relevant Australian Standards
 3. All the safety related issues shall be addressed as per relevant Australian Standards
 4. Design is compliant with AS5033/2021
 5. All DC and earth cable sizes shall be min 4mm² per conductor unless otherwise noted.

TITLE
Design Site Layout

REVISION DESCRIPTION	HCB SOLAR	Project Management	Client	Michael Haggerston	SCALE: NTS			
		HCB SOLAR	Project	106 School Lane, Budgee Budgee	DRAWN BR	CHECKED BR	APPROVED BR	DATE
Construction		Solar Design	Job No.	30034			13/01/25	S7647070
		HCB SOLAR			Version:	Design_Tool_HCB		
					Date:	12/06/2024		