

## SEWER TREATMENT PLANTS - Environmental Compliance

01 April 2024 -31 March 2025

Gulgong Wastewater Treatment Plant  
107 Spring Creek Road, Gulgong NSW 2852

Environment Protection Licence: 5808 <http://www.epa.nsw.gov.au/prpoeoapp/>

Monitoring Point 2		pH	EC	TDS (calculated)	TSS	Chlorine total residual	Total Nitrogen	Total Phosphorus	Chlorophyll a	Oil & Grease	BOD	Faecal Coliforms	Report Generated	Comments
Pollutant														
Limits			µs/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/m3	mg/L	mg/L	CFU/100mL		
Units														
Date sampled	Date results received													
17/04/2024	24/04/2024	8.3	1060	710	7	<0.2	2.9	3.70	<1	<2	3	56	26/04/2024	
15/05/2024	22/05/2024	8.6	1030	690	4	<0.2	2.5	2.58	2	<2	8	70	23/05/2024	
12/06/2024	19/06/2024	8.4	1020	683	3	<0.2	1.9	2.28	<1	<2	20	5	16/06/2024	
10/07/2024	16/07/2024	8.9	983	659	2	<0.2	1.7	2.00	2	<2	2	8	17/07/2024	
				0										
				0										
				0										
				0										
				0										
				0										
				0										
				0										
<b>No of samples taken</b>		4	4	12	4	4	4	4	2	4	4	4		
<b>Samples/year required by EPA</b>		12			12	12	12	12		12	12	12		
<b>Minimum</b>		8.3	983	0	2.0	0.1	1.7	2.00	2	1.0	2.0	5		
<b>Average</b>		8.6	1023	229	4.0	0.1	2.3	2.64	2	1.0	8.3	35		
<b>Maximum</b>		8.9	1060	710	7	0.1	2.9	3.70	2	1	20	70		



